Mat3

Material review report

MAT3 HOSTED QA · PUBLIC NIGERIAN DOCUMENT EVALUATION

Material item	IOM Lagos BOQ · floor Option 1 · public test
Intended use	Public-document evaluation: Option 1 floor tiles, three explicitly selected attributes; not a live project approval
Supplier	CDK Industries · public catalogue evaluation
Selected product	Menandro 600x1200mm Ultra Polish · Menandro
Requirements / submission	Baseline v1 / Revision 1
Recorded by	Mat3 deployment test reviewer · mat3-reviewer-627255b9@deployment-test.invalid
Recorded at	11 October 2026, 16:12 WAT

Revise And Resubmit

Public-document evaluation only. Reviewer selected floor Option 1 (size, polished finish, 8 mm thickness) from the IOM BOQ. The CDK catalogue excerpt has a documented conflict and no thickness statement. This is a test decision, not an IOM approval or rejection of CDK products.

Findings and sources

MATCHES

Surface finish

Required: Polished
Submitted: Ultra Polish

The documented value supports the approved requirement.

> **Requirement · Page 9**
>
> “OPTION 1: 600x 600 x 8mm thick polish ceramic floor tiles of approved colour laid on screeded bed with cement and sand mortar (1:3) (measured separately)”
>
> Document af978a38-9c22-4d0e-b4fd-63be77fad75b · Source block e8f3db00-7689-409a-a220-bf966352df76

> **Supplier · Page 1**
>
> “Ultra Polish”
>
> Document c218aa6b-31bb-4691-8ec6-1f615bfb9f65 · Source block 5a32bcc9-b443-43e6-880a-2e2910c5fa60

CONFLICTS

Dimensions

Required: 600 × 600 mm
Submitted: 600x1200mm

The documented value differs from the approved requirement.

> **Requirement · Page 9**
>
> “OPTION 1: 600x 600 x 8mm thick polish ceramic floor tiles of approved colour laid on screeded bed with cement and sand mortar (1:3) (measured separately)”
>
> Document af978a38-9c22-4d0e-b4fd-63be77fad75b · Source block e8f3db00-7689-409a-a220-bf966352df76

> **Supplier · Page 1**
>
> “600x1200mm”
>
> Document c218aa6b-31bb-4691-8ec6-1f615bfb9f65 · Source block 5a32bcc9-b443-43e6-880a-2e2910c5fa60

MISSING EVIDENCE

Thickness

Required: 8 mm
Submitted: Not provided

No supporting statement was found in the fully processed submission scope.

> **Requirement · Page 9**
>
> “OPTION 1: 600x 600 x 8mm thick polish ceramic floor tiles of approved colour laid on screeded bed with cement and sand mortar (1:3) (measured separately)”
>
> Document af978a38-9c22-4d0e-b4fd-63be77fad75b · Source block e8f3db00-7689-409a-a220-bf966352df76

Review record

This report preserves the inputs, machine findings and reviewer corrections at the time of the recorded decision. It describes document evidence; it does not authenticate certificates or verify physical material quality.

Analysis 3a91ca67-446f-4460-90e6-5377d12f151d
Baseline ce07fdfd-e199-4cc1-8ffe-0629ffcb9124 · Submission 07c7fbf1-1e69-4483-985d-7db5cc5ef211
Model gemini-3.8-flash · Prompt materials-extraction-1.1.0 · Rules materials-1.2.0 · Parser document-parser-1.0